

This report is a summary of the quality of water the City of North Richland Hills provides to customers. The analysis was made by using data from the most recent U.S. Environmental Protection Agency (EPA) required testing and is presented in the following information. We hope this information helps you become more knowledgeable about what's in your drinking water.

### **En Español**

Este reporte incluye importante información sobre el agua potable. Si tiene preguntas ó comentarios sobre este reporte, puede comunicarse con una representante bilingüe al teléfono (817) 427-6440.

### **Where do we get our drinking water?**

The City of North Richland Hills purchases water from the City of Fort Worth and the Trinity River Authority (TRA).

### **State Agency Assessed Source Waters**

The City of Fort Worth uses surface water from Lake Worth, Eagle Mountain Lake, Lake Bridgeport, Richland Chambers Reservoir, Cedar Creek Reservoir, Lake Benbrook and the Clear Fork Trinity River.

The Trinity River Authority (TRA) uses surface water from Lake Arlington.

TCEQ (Texas Commission on Environmental Quality) completed an assessment of your source water. TCEQ classified the risk to our source waters as high for most contaminants. High susceptibility means there are activities near the source the source water or a watershed make it very likely that chemical constituents may come into contact with the source water. It does not mean that there are any health risks present. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contamination may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Public Works at (817) 427-6457 or email [tngo@nrhtx.com](mailto:tngo@nrhtx.com).

The assessment report consists of maps showing the assessment area, an inventory of known land use activities of concern and documentation of specific contaminants of concern. The report is available by contacting the Fort Worth Water Department office at 1000 Throckmorton Street in Fort Worth, Texas or the Trinity River Authority at 11201 Trinity Boulevard in Euless, Texas.

More information about the source water assessments is available online at:

[www.tceq.texas.gov/drinkingwater/SWAP/index\\_swa.html](http://www.tceq.texas.gov/drinkingwater/SWAP/index_swa.html)



## **EVERY DROP OF WATER COUNTS CONSERVE TODAY FOR TOMORROW.**

### **Special Notice For THE ELDERLY, INFANTS, CANCER PATIENTS, People With HIV/AIDS Or Other Immune Problems**

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. EPA/Centers for Disease Control and Prevention (CDC) offers guidelines on the appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the EPA's Safe Drinking Water Hotline at 1 (800) 426-4791.

### **All Drinking Water May Contain Contaminants**

When drinking water meets federal standards, there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline 1 (800) 426-4791.

### **Public Participation Opportunities**

If you have concerns or questions about North Richland Hills' drinking water quality, or would like to request a speaker on this topic for a group or organization meeting, please call (817) 427-6457 or visit the City's website ([www.nrhtx.com](http://www.nrhtx.com)).

North Richland Hills' governing body, the City Council, meets the second and fourth Monday of the month at 7:00 p.m. at City Hall. Citizens are encouraged to attend Council Meetings. Please call (817) 427-6060 for information about the Council Meetings.

**The following information lists all of the federally regulated or monitored constituents which have been found in your drinking water for 2018 calendar year.**

**Secondary Constituents**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA.

These constituents are not causes for health concerns. Therefore, secondary constituents are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

**Cryptosporidium, Giardia & Viruses Monitoring**

The 2018 sampling of lake water showed low level detections of Giardia Lamblia, which is common in surface water. This micro pathogen which may be found in water contaminated by feces. Cryptosporidium and viruses were not detected in any of the samples.

Required levels of inactivation are achieved through disinfection and filtration. Although filtration removes Cryptosporidium, it cannot guarantee 100 percent removal nor can the testing methods determine if the organisms are alive and capable of causing Cryptosporidium, an abdominal infection with nausea, diarrhea and abdominal cramps may occur after ingestion of contaminated water. No specific drug therapy has proven effective, but people with healthy immune systems usually recover within two weeks. Individuals with weak immune systems, however, may be unable to clear the parasite and suffer chronic and debilitating illness.

**What Is In The Water**

The following charts list the contaminants that require monitoring or are regulated and detected in North Richland Hills' water. The data included is from calendar year 2018 unless otherwise indicated. In addition, since North Richland Hills purchases its water from the City of Fort Worth and Trinity River Authority, the levels included are a compilation of both entities annual sampling results with the highest detected levels being shown.

**Lead and Copper**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and private plumbing.

The City of North Richland Hills is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the EPA's Safe Drinking Water Hotline 1 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

**North Richland Hills's water did not exceed any of the regulated limits in 2018.**

**North Richland Hills Water Loss for 2018**

For the calendar year 2018, our system lost an estimated 136,644,255 gallons of water per the audit submitted to the Texas Water Development Board. Water loss was caused by water main breaks, fire hydrant flushing, and unauthorized usage.

If you have any question about the water loss audit please call (817) 427-6457.

**Abbreviations used in tables**

**Maximum Contaminant Level (MCL)** - The highest permissible level of a contaminant in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected health risk. MCLG's allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Report Level (MRL)**. The lowest concentration of a contaminant that can be measured by a laboratory.

**N/A** - Not Applicable.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**NTU** - Nephelometric Turbidity Units (a measure of water turbidity or clarity)

**pCi/L** - picocuries per liter (a measure of radioactivity).

**ppm** - parts per million or milligrams per liter (mg/L).

**ppb** - parts per billion or micrograms per liter (ug/L).

## Regulated Contaminants

Contaminant	Unit	MCL	MCLG	NRH Water	Range of Detection	Violation	Common Sources of Substance
Arsenic	ppb	10	0	1.1	0 to 1.1	NO	Erosion of natural deposits; runoff from orchards; runoff from grass and electronics production wastes.
Atrazine	ppb	3	3	0.3	0 to 0.3	NO	Runoff from herbicides used on row crops.
Barium	ppm	2	2	0.07	0.04 to 0.07	NO	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Beta particles & <sup>1</sup> Photon emitters	pCi/L	50	0	5.6	4.4 to 5.6	NO	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation.
Bromate	ppb	10 <sup>2</sup>	0	10.7	0 to 10.7	NO	By-product of drinking water distribution.
Combined <sup>1</sup> Radium	pCi/L	5	0	2.5	N/A	NO	Erosion of natural deposits.
Cyanide	ppb	200	200	84.3	0 to 84.3	NO	Discharge from plastic and fertilizer factories; discharge from steel and metal factories.
Fluoride	ppm	4	4	0.61	0.17 to 0.61	NO	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Nitrite (measure as Nitrogen)	ppm	1	1	0.02	0. to 0.02	NO	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Simazine	ppb	4	4	0.11	0.11 to 0.11	NO	Herbicide runoff.
Turbidity	NTU	TT = 1.0	N/A	0.5	0 to 0.5	NO	Soil runoff (Turbidity is a measure of the cloudiness of water. It is monitored because it is a good indicator of the effectiveness of the filtration system.)
	%	TT =95	100	100	99.9 to 100		
Uranium <sup>1</sup>	ppb	30	0	1.1	0 to 1.1	NO	Erosion of natural deposits.

<sup>1</sup> Because Fort Worth historically has had low levels of radionuclides in its water, TCEQ requires this monitoring occur only once every six years. The test results shown above are from 2017. The next monitoring will occur in 2023.

<sup>2</sup> Compliance is based on Running Annual Average of monthly average for Bromate at the end of each quarter, which has less than 5 ppb for each quarter in 2018.

## Regulated in the Distribution System

Contaminant	Unit	MCL	MCLG	NRH Water	Range of Detection	Violation	Common Sources of Substance
Nitrate (measured as Nitrogen)	ppm	10	10	1	0.29 to 0.629	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Haloacetic Acids <sup>3</sup> (HAA5)	ppb	60	N/A	30	5.8 to 24.8	N	By-product of drinking water disinfection.
Total Trihalomethanes <sup>3</sup> (TTHM)	ppb	80	N/A	36	6.6 to 37.7	N	
Total Coliforms <sup>4</sup> (including fecal coliform & E. Coli)	% of positive samples	Present in 5% of samples	0	0%	0	N	Coliforms are naturally present in the environment as well as feces; fecal coliforms and E-coli only come from human and animal fecal waste.
Contaminant	Unit	MRDL	Ideal Goal (MRDLG)	North Richland Hills Water	Range of Detections	Violation	Common Sources of Substance
Chloramines	ppm	4	4	0.5 to 3.9	0.5 to 3.9	N	Water additive to control microbes.
Contaminant	High	Low	MCLG	Range of Detections	MCL	Violation	Common Sources of Substance
Total Organic Carbon <sup>5</sup>	1.37	1.0	N/A	1.0 to 1.37	TT = 1.0 removed	N	Naturally occurring.

<sup>3</sup> Initial Distribution System Evaluation for Disinfection Byproduct—This evaluation is sampling required by EPA to determine the range of total Trihalomethanes and Haloacetic acid in the system. Some of these samples are regulated and some are non-regulated. In all cases the samples were less than the highest allowed MCL. EPA also requires the data to be reported here.

<sup>4</sup> No more than 5.0% samples of coliform-positive in a month. Every sample that has total coliform must be analyzed for either fecal coliforms or E. coli. If two consecutive total coliforms-positive samples, and one is also positive for E-coli fecal coliforms, system has an acute MCL violation.

<sup>5</sup> Total Organic Carbon is used to determine disinfection by-product precursors. North Richland Hills was in compliance with all monitoring and treatment technique requirements for disinfection by-product precursors. Removal ratio is the present TOC removed by the treatment process divided by the percent of TOC removal required by TCEQ.

## Regulated at the Customer's Tap

Contaminant (Units)	90 <sup>th</sup> percentile values <sup>6</sup>	No. of Sites Exceeding Actions Level	MCL	MCLG	Violation	Common Sources of Substance in Drinking Water
Lead <sup>7</sup> (ppb)	3	0	Action Level = 15	0	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Copper <sup>7</sup> (ppm)	0.3	0	Action Level = 1.3	1.3	N	Corrosion of household plumbing systems; Erosion of natural deposits.

<sup>6</sup> 90<sup>th</sup> percentile value: 90% of the samples were at or below this value. EPA considers the 90th percentile value the same as an "average" value for other contaminants. Lead and copper are regulated by a treatment technique that requires systems to control the corrosiveness of their water. If more than 10% of tap water samples exceed the action level, water systems must take additional steps.

<sup>7</sup> The test results shown above are from 2018 .

## Unregulated Contaminants <sup>8</sup>

Contaminant (Units)	MCL	MCLG	NRH Water	Range of Detections	Common Sources of Substance
Chloral hydrate (ppb)	Not regulated	None	0..34	0.12 to 0.34	By-product of drinking water disinfection.
Bromoform (ppb)	Not regulated	None	5.15	0 to 5.15	By-product of drinking water disinfection; not regulated individually; included in Total Trihalomethanes.
Bromodichloromethane (ppb)	Not regulated	None	13.4	1.99 to 13.4	
Chloroform (ppb)	Not regulated	70	17.2	2.43 to 17.2	
Dibromochloromethane (ppb)	Not regulated	60	7.84	1.31 to 7.84	
Monochloroacetic Acid (ppb)	Not regulated	70	3.9	1.5 to 3.9	By-product of drinking water disinfection; not regulated individually; included in Haloacetic Acids.
Dichloroacetic Acid (ppb)	Not regulated	None	13	3.9 to 13	
Trichloroacetic Acid (ppb)	Not regulated	20	5.6	0 to 5.6	
Monobromoacetic Acid (ppb)	Not regulated	None	2.3	0 to 2.3	
Dibromoacetic Acid (ppb)	Not regulated	None	4.3	1 to 4.3	

<sup>8</sup> Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

## Additional Parameters

This chart lists other items for which the water is tested. These items do not relate to public health but rather to the aesthetic effects. These items are often important to industrial users.

ITEM	UNIT OF MEASURE	NORTH RICHLAND HILLS WATER
Acetone	ppb	6.7 to 6.7
Aluminum	ppb	55 to 55
Bicarbonate	ppm	92.2 to 144
Calcium	ppm	35.3 to 52.1
Chloride	ppm	11.8 to 40
Conductivity	umhos/cm	302 to 471
Copper	ppb	32 to 32
Magnesium	ppm	3.2 to 8.64
Manganese	ppb	0 to 20
Methyl Ethyl Ketone	ppb	.6 to .6
Nickel	ppb	2.1 to 2.1
pH	units	7.1 to 8.9
Potassium	ppm	4.5 to 4.5
Silver	ppm	0.002 to 0.002
Sodium	ppm	14.8 to 30.3
Sulfate	ppm	26.3 to 52.1
Total Alkalinity as CaCO <sub>3</sub>	ppm	92.2 to 136
Total Dissolved Solids	ppm	156 to 251
Total Hardness as CaCO <sub>3</sub>	ppm	107 to 162
Total Hardness in grains	grains/gallons	7.0 to 9.0

## Source Water Assessments

As indicated previously in this report, the City of North Richland Hills purchases treated water from the City of Fort Worth and Trinity River Authority. North Richland Hills is also capable of utilizing well water, however, it is seldom required. In 2003, the Texas Commission on Environmental Quality completed source water assessments on all seven (7) drinking water sources for Fort Worth and the Trinity River Authority raw water source. The source water assessments describe the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in this assessment will allow us to focus on source water protection strategies. More information about source water assessment and protection can be found at <http://cfpub.epa.gov/safewater/sourcewater/> or you can contact Regulatory Compliance Office at 817-427-6457 or email [nrhpw@nrhtx.com](mailto:nrhpw@nrhtx.com) for more information.

## City of North Richland Hills' UCMR3 Testing Information

### Data gathering to determine if more regulation needed

Water utilities in the United States monitor for more than 100 contaminants and must meet 91 regulations for water safety and quality.

But should other contaminants be regulated? The 1996 Safe Drinking Water Act amendments require that once every five years EPA issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems. This monitoring provides a basis for future regulatory actions to protect public health.

The first Unregulated Contaminant Monitoring Rule (UCMR 1) was published on Sept. 17, 1999, the second (UCMR 2) was published on Jan 4, 2007 and the third (UCMR 3) was published on May 2, 2012. North Richland Hills did not detect any of the contaminants in the UCMR 1 and UCMR 2 testing.

The third Unregulated Contaminant Monitoring Rule (UCMR3) includes assessment for 21 chemical contaminants, 7 hormones and two viruses. The virus testing did not impact North Richland Hills. This testing was limited to small groundwater systems that do not disinfect.

UCMR benefits the environment and public health by providing EPA and other interested parties with scientifically valid data on the occurrence of these contaminants in drinking water. Health information is necessary to know whether these contaminants pose a health risk.

Public water systems sampled for these contaminants for four consecutive quarters in 2014. North Richland Hills' sampling occurred from Jan 2014 through Dec 2014. The results shown are for the four quarters of sampling.

The following information is provided by the City of North Richland Hills.

#### Additional Information:

[Water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/ucmr3/index.cfm](http://Water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/ucmr3/index.cfm)

UCMR 3					
North Richland Hills' testing detected only 6 of the 21 chemical contaminants and none of the seven hormones.					
Contaminant	Measure	Range of Detects	2014 Level	MRL	Common Sources of Substance
Bromochloromethane (Halon 1011)	ppb	66 to 82	82	60	Used as a fire-extinguishing fluid, an explosive suppressant, and as a solvent in the manufacturing of pesticides
Vanadium	ppb	0.26 to 3.8	3.8	0.2	Naturally-occurring elemental metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst
Molybdenum	ppb	1.4 to 1.9	2.5	1	Naturally-occurring element found in ores and present in plants, animals and bacterial; commonly used form molybdenum trioxide used as chemical reagent
Strontium	ppb	58 to 340	340	0.3	Naturally-occurring element; historically, commercial use of strontium has been in the faceplate class of cathode-ray tube televisions to block x-ray emissions
Chromium <sup>9</sup>	ppb	0.23 to 2.8	2.8	0.2	Naturally-occurring element; used in making steel and other alloys; chromium-3 or -6 forms are used for chrome plating, dyes and pigments, leather tanning and wood preservation
Chromium-6	ppb	0 to 0.14	0.14	0.03	
Chlorate	ppb	20 to 260	260	20	Agricultural defoliant or desiccant; disinfection byproduct; and used in production of chlorine dioxide
<sup>9</sup> Total Chromium, the sum of chromium in all its valence states, is already regulated in drinking water. As part of UCMR3, EPA requires testing for Total Chromium in the same samples used to test for Chromium 6, which is on the UCMR3 list. The MCL for EPA's current total chromium regulation was determined based upon the health effects of Chromium 6.					

### UCMR 3 contaminants not detected

#### Chemicals

1,2,3-trichloropropane  
 1,3-butadiene  
 chloromethane (methyl chloride)  
 1,1-dichloroethane  
 bromonethane  
 chlorodifluoromethane (HCFC-22)  
 1,4-dioxane  
 cobalt  
 perfluorooctanesulfonic acid (PFOS)  
 perfluorooctanoic acid (PFOA)  
 perfluorononanoic acid (PFNA)

perfluorohexanesulfonic acid (PFHxS)  
 perfluoroheptanoic acid (PFHpA)  
 perfluorobutanesulfonic acid (PFBS)

#### Hormones

17-β-estradiol  
 17-α-ethynylestradiol  
 estriol  
 equilin  
 estrone  
 testosterone  
 4-androstene-3,17-dione

2018 water quality data for wholesale customers